

PHYSICAL TESTING REPORT



Metamark UK Ltd
Metamark House
Octimum Business Park
Forsyth Road
Woking
Surrey
GU21 5JF

FAO: Mr. Max Somper

Report of Tests on: MetaWalk

Your Reference: Metamark MD-MW

Lucideon Reference: UK201936-15028

Date Reported: 26-May-2020

Order Number: MS300420

Date Logged: 05-May-2020

Date(s) of Test(s): 20-May-2020 to 20-May-2020

Inclined Platform Test for Slip Resistance In Shod Conditions

DIN 51130:2014

No.	Operator 1 - Angle of Inclination	Operator 2 - Angle of Inclination
	°	°
1	11.6	11.9
2	10.9	12.6
3	11.7	12.8

Description of Test Specimen(s): 1 metawalk sheet

Average of Six Shod Results (Corrected): 13.0 °

Category: R10

The critical angle at which a test person reaches the limit of safe walking on an inclined plane is used as a measure of slip resistance.

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

End of Test Report

Mr Simon Hall
Manager

This report is issued in accordance with the Conditions of Business of Lucideon Limited and relates only to the sample(s) tested. No responsibility is taken for the accuracy of the sampling unless this is done under our own supervision. This report shall not be reproduced in part without the written approval of Lucideon Limited, nor used in any way as to lead to misrepresentation of the results or their implications.

Lucideon is the trading name of Lucideon Limited. Registered in England No. 1960455.

Lucideon Limited
Queens Road, Penkhull
Stoke-on-Trent
Staffordshire ST4 7LQ

T +44 (0)1782 764428
enquiries@lucideon.com
www.lucideon.com